



**INTERPRETATIONS & APPLICATIONS  
OF BUILDING CODES & REGULATIONS #95-4**

**CODE SECTION :                   IMC 301.12, 301.15, IRC 1307.1**

**02/06/02 rev. 9/16/03**

**SUBJECT :   MECHANICAL EQUIPMENT ON ROOFS**

HVAC equipment or other equipment located on roofs must be mounted on curbs with appropriate flashing, or mounted on steel angle frames with "pitch pocket" flashing. Other designs which provide positive mechanical attachment, and do not penetrate the roof membrane will be considered.